



Bulletin # 17-03 Feb 2011

BULLETIN: DYNAFORCE AND POWER VENTING SYSTEMS

Use of Power Venting Devices with multiple Dynaforce Boilers and / or Water Heaters:

Camus Hydronics Ltd. Dynaforce series units have a design draft pressure of -0.05" w.c. and a maximum allowable draft of -0.15" w.c.

The addition of Power Venting System must maintain pressures within the allowable draft range. Options are available to meet these needs from manufacturers such as ENERVEX and TJERNLUND. Power venting manufacturer's instruction to meet the allowable draft ranges must be followed.

Installer must be certain that each unit is interlocked with the external fan.

Units will operate without issue provided the above criteria is met.

David Procnier
Engineering/Technical Support



**514 Mecham Avenue
Elmont, New York 11003
Ph: (516) 327-4870
www.mjdcombustion.com**